

CITY OF SAN LEANDRO

INVITATION FOR BIDS

SUBMIT BID TO: City of San Leandro Purchasing Department 835 East 14th Street San Leandro, CA 94577	FOR FURTHER INFORMATION CONTACT: Don Brockman Purchasing Agent (510) 577-3472 fax (510) 577-3312 dbrockman@sanleandro.org
--	--

BID NO:	DATE MAILED:	THIS BID MUST BE DELIVERED TO THE CITY BEFORE:
13-14.011	November 19, 2013	3:00 PM, Tuesday, December 17, 2013

QTY.	DESCRIPTION	UNIT PRICE	EXTENSION
TWO (2) EACH	<p align="center">TWO (2) REPLACEMENT POLYETHYLENE SODIUM HYPOCHLORITE TANKS Bid No. 13-14.011 Notice to Bidders</p> <p>Provide two (2) Replacement Polyethylene Sodium Hypochlorite Tanks in accordance with the specifications attached to this bid.</p> <p>Make/Model: _____</p> <p>Specify Warranty: _____</p> <p>Delivery Date: _____</p> <p>All specifications are minimum requirements, unless otherwise noted.</p> <p><u>All bidders must submit with their proposal sufficient literature to show compliance with specifications.</u> Any deviations from specifications must be clearly indicated in writing at the time the proposal is submitted. The City reserves the right to waive minor variations in specifications bid.</p> <p>Questions related to this bid may be submitted in writing to the Purchasing Agent at the address above or via email to: dbrockman@sanleandro.org</p> <p>Do not include sales tax in your bid. Sales tax will be added to the purchase order and remitted with invoice payment.</p> <p>State your earliest delivery date as requested. This date may be an important factor in award determination.</p> <p>Sealed bids shall be received at the Finance/Purchasing Office, City Hall, 2nd Floor, 835 E. 14th Street, San Leandro, CA up to 3:00 P.M., Tuesday, December 17, 2013 at which time they will be publicly opened and read.</p>	<p>\$ _____ EACH</p> <p>DELIVERY CHARGE <i>(if not included in price)</i></p>	<p>\$ _____ TOTAL</p> <p>\$ _____</p> <p>\$ _____ GRAND TOTAL</p>

Any bid may be withdrawn at any time prior to the time fixed for the opening of bids only by written request for the withdrawal of the bid filed with the City. The request shall be executed by the bidder or bidder's duly authorized representative. The withdrawal of a bid does not prejudice the right of the bidder to file a new bid. Whether or not bids are opened exactly at the time fixed in the public notice for opening bids, a bid will not be received after that time nor may any bid be withdrawn after the time fixed in the public notice for opening of bids.

As stated in Public Contract Code Section 5100 to 5108, inclusive (State Contract Act) concerning relief of bidders and in particular to the requirement therein, that if the bidder claims a mistake was made in his bid, the bidder shall give the City written notice within five (5) days after the opening of the bids of the alleged mistake, specifying in the notice, in detail how the mistake occurred.

All bidders shall verify if any addendum for this project has been issued by the City. It is the bidder's responsibility to ensure that all requirements of contract addendum are included in the bidder's submittal.

The award will be made to the lowest responsible bidder whose bid complies with the specifications in a manner satisfactory to the City's best interests as determined by the City. The right is reserved, as the interest of the City may require, to reject any or all bids, or to waive any informality or minor irregularity in the bids.

Payment shall be within 30 days following acceptance of bid items.

To bid, complete and return a copy of the Request and any other required forms, in a sealed envelope. The envelope shall be marked with the project name and bid number. The bid must be received by the date and time shown in order to be considered. Deliver envelope to: City of San Leandro Purchasing Dept., 835 E. 14th Street, San Leandro, CA, 94577. Please note that there is a one-day delay in mail delivery to City Hall by the U.S. Postal Service.

Delivery of materials shall be to:

**City of San Leandro Water Pollution Control Plant
3000 Davis Street
San Leandro, CA 94577**

Firm _____

Date: _____

Address _____

Phone: _____

FAX: _____

By (Signature) _____

Print Name: _____

Title: _____



Don Brockman
Purchasing Agent

TWO (2) REPLACEMENT POLYETHYLENE
SODIUM HYPOCHLORITE TANKS

Bid No. 13-14.011

Notice to Bidders

SPECIFICATIONS

The following specifications are minimum unless otherwise specified.

PART 1 – SCOPE/STANDARDS

- A. Successful bidder to provide two (2) polyethylene tanks suitable for outdoor installation and designed for use with sodium hypochlorite 13% solution
- B. Bid is **not** to include installation, seismic restraints, on-site factory startup or training, bid is strictly for the tanks and delivery, installation to be done on site by City staff
- C. Tanks to meet or exceed all local, state and federal safety standards and regulations

PART 2 SPECIFICATIONS

- A. Tanks to be designed for use with sodium hypochlorite 13% solution
- B. Maximum Diameter: 12'-5"
- C. Maximum Height: 12'-0"
- D. Minimum nominal capacity: 5000 gallons
- E. Maximum nominal capacity: 6000 gallons
- F. Factory molded outlet/drain 3" minimum diameter
- G. Float style exterior level indicator
- H. 6" top mounted level flange (for ultrasonic level transducer)
- I. 6" top mounted outlet for vent
- J. 2" top mounted inlet
- K. Man-way
- L. 5-year warranty