

**City San Leandro Bid Results Summary –
 Bid Number 13-14.011, TWO (2) TANKS FOR WPCP HYPOCHLORITE
 Tuesday, December 17, 2013 3:00 PM**

COMPANY NAME	MAKE/MODEL	EXCEPTIONS	WARRANTY/ DELIVERY	BID PRICE EACH	DELIVERY CHARGE	TOTAL
BURLINGAME ENGINEERS	Poly Processing 6100 gallon IMFO	Max. height = 12'7" Max capacity = 6100 gallons	5 years 3-4 weeks	\$9998.00	\$800.00	\$20,796.00
PROTANK	Snyder 7000000N52	None noted	5 years 6 weeks lead time	\$15,290.00	N/C	\$30,580.00
RYAN PROCESS	Snyder 7140300N	None noted <i>(spec sheet shows overall height of 145.8")</i>	5 years Presently 4 weeks	\$13,270.00	\$1400.00	\$27,940.00
<p>Note: 12' max height based on utilizing City owned equipment to place and install tank, over 12' City will need to rent equipment at cost of <\$2500 to place tank. Both Burlingame – 12'7" and Ryan Process – 145.08" exceed the max height, but cost of renting equipment to install the lower priced Burlingame tank is less than the extra cost to purchase the Protank, resulting in savings to the City on tanks that will meet the City's needs, therefore the City waives as minor the variation in specifications bid by Burlingame.</p>						