



NOTES:

1. All work be done in accordance with the Standard Specifications for Public Works Construction, the "GREENBOOK", the most current edition and all supplements thereto, adopted by the Southern California Chapter of the American Public Works Association and the Special Provisions (Technical Specifications) thereto adopted by the City.
2. Place fire hydrant behind sidewalk where sidewalk and curb is a total of 1.8m (6') wide or less.
3. Fire hydrant and pad must be within street right-of-way or P.U.E.
4. Do not locate street light or tree at same property line junction as fire hydrant.

ACAD FILE: C3101D142.DWG.

CITY OF SAN LEANDRO * STANDARD PLANS

NO.	REVISIONS	DATE	FIRE HYDRANT LOCATION			APPROVED			
						Kenneth Joseph, City Engineer R.C.E. No. 34870 Expires 9/30/03			
DRAWN GF/MLWH/VL		CHECKED KJ/KRC	DATE May 2002	SCALE NONE	SHEET 1 OF 1	DWG. NO. 142	CASE. 3101		