



NOTES:

1. All work shall be done in accordance with the Standard Specifications for Public Works Construction, the "GREENBOOK", the most current edition and all supplements thereto, adopted by the Southern California Chapter of the American Public Works Association and the Special Provisions (Technical Specifications) thereto adopted by the City.
2. Insulated Backflow Preventer Enclosure shall be Strong Box Model SBBC-ALI by V.I.T. Products, Inc., 1-800-729-1314, or approved equal, sized per backflow preventer. 50mm (2") min. clear top and 100mm (4") min. clear all sides between enclosure and any pipe or fittings. Field measure for verification prior to ordering enclosure.
3. Refer to Backflow Preventer Assembly Dwg. 408 Case 3101.
4. General Concrete Notes Dwg. 104 Case 3101 shall apply.

ACAD FILE NO. C3101D410.dwg

CITY OF SAN LEANDRO * STANDARD PLANS

NO.	REVISIONS	DATE	BACKFLOW PREVENTER ENCLOSURE				APPROVED	
							Kenneth Joseph, City Engineer R.C.E. No. 34870 Expires 9/30/03	6/24/02
DRAWN GF/MLWH/VL		CHECKED KJ/KRC	DATE May 2002	SCALE NONE	SHEET 1 OF 1	DWG. NO. 410 CASE. 3101		