


PLAN
NO SCALE

Stabilize subgrade as necessary to provide unyielding support. Place crushed stone on approved geotextile fabric



PROFILE
NO SCALE

1. All work shall be done in accordance with the Standard Specifications for Public Works Construction, the "GREENBOOK", the most current edition and all supplements thereto, adopted by the Southern California Chapter of the American Public Works Association and the Special Provisions (Technical Specifications) thereto adopted by the City.
2. The material for construction of the pad shall be 50mm to 75mm (2 to 3 inch) crushed open graded stone ("drain rock" or "cobbles") placed on approved geotextile fabric.
3. The thickness of the pad shall not be less than 200mm (8 inches) placed on approved geotextile fabric.
4. The width of the pad shall not be less than the full width of all points of ingress or egress.
5. The length of the pad shall be as required, but not less than 15m (50 feet).
6. The entrance shall be maintained in a condition that will prevent tracking or flowing of sediment onto public rights-of-way. This may require periodic top dressing with additional stone as conditions demand, and repair and/or cleanout of any measures used to trap sediment. All sediment spilled, dropped, washed or tracked onto public rights-of-way shall be removed immediately.
7. When necessary, wheels shall be washed to remove sediment prior to entrance onto public rights-of-way. When washing is required, it shall be done on an area stabilized with crushed stone that drains into an approved sediment trap or sediment basin, or a commercial self contained wheel washing apparatus shall be provided. All sediment shall be prevented from entering any storm drain, ditch or watercourse through use of sand bags, gravel, hay bales, geotextile fabrics or other approved methods.

ACAD FILE NO. C31010606.dwg

CITY OF SAN LEANDRO * STANDARD PLANS

NO.	REVISIONS	DATE

STABILIZED CONSTRUCTION ENTRANCE

APPROVED *[Signature]* 6/24/02
 Kenneth Joseph, City Engineer R.C.E. No. 34870
 Expires 9/30/03