

**LEWELLING BOULEVARD LANDSCAPE MEDIANS  
05-210-38-231**

**ADDENDUM NO. 2**

November 15, 2005

TO: All Prospective Bidders

The additions and/or deletions contained in this Addendum shall be made a part of the plans and specifications and contract documents for the above described project, and shall be subject to all applicable requirements there under, as if originally shown and/or specified.

**THE CONTRACT BOOK SHALL BE REVISED AS FOLLOWS:**

1. Item 3 of **Section 202-3** is revised to read:

3. Filter Fabric- Filter fabric shall conform to Section 213-2 "Geosynthetics" of the Standard Specifications. Fabric shall be type 140N.

2. The following shall be added to **Section 300-2.1**:

The soil in the areas of excavation have been sampled and tested. The results of the tests are in a report prepared by Kleinfelder entitled, "Results of Chemical Analyses on Soil Samples for Lewelling Boulevard Landscape Medians". In the Conclusions and Recommendations section of the report it states, "Based on the above-described results of the chemical analyses, it is Kleinfelder's opinion that the soil...appears to be non-hazardous, and is suitable for either onsite reuse, commercial/industrial site use, or disposal at a Class III disposal facility."

A summary of the data appears in the enclosed Table I-Soil Analytical Data Soil Samples, Lewelling Boulevard Medians, San Leandro, California November 1, 2005.

The entire report may be viewed at the City of San Leandro Engineering and Transportation Department.

**THE CONTRACT PLANS SHALL BE REVISED AS FOLLOWS:**

3. On **Sheet 5** the following is added to Demolition Note No. 10:

The soil in the areas of excavation have been sampled and tested. See Section 300-2.1 of the Special Provisions.

**PLEASE NOTE:**

**The Bid Opening Date Remains as Stated in Addendum No. 1 on  
Monday, November 21, 2005 at 3:00 P.M.**

Lewelling Boulevard Landscape Medians Addendum No. 2  
Project No. 05-210-38-231  
November 15, 2005  
Page 2 of 3

Acknowledge this addendum in your Proposal. If you have any questions, please call the Project Engineer, Marian Scholle, at (510) 577-3375.

Very truly yours,

Kenneth Joseph, P.E., City Engineer  
Engineering and Transportation Department

KJ/MCS:km

Lewelling Boulevard Landscape Medians Addendum No. 2  
Project No. 05-210-38-231  
November 15, 2005  
Page 3 of 3

**ACKNOWLEDGEMENT**

I hereby acknowledge receipt of this Addendum for the above noted project.

\_\_\_\_\_ Date: \_\_\_\_\_  
(Signature)

\_\_\_\_\_  
(Business Name – Please Print)

cc: Internal Plans & Specs Distribution List  
COSL Current Plan-holders and Pre-bid Meeting Attendees