



City of San Leandro

Purchasing Division

Addendum No. 1 – Bid specifications 07-08.011, San Leandro Boys and Girls Club Re-Piping

November 16, 2008

Note # 3 on plan sheet – Add - Check valve will be flanged and serviceable

Note # 15 on plan sheet – Add – All valves 2” and smaller will be ball type and non-flanged

In addition:

All valves greater than 2” will be flanged butterfly valves

Drain from 500 gallon holding tank will be 2” PVC with valve

Signature of Bidder

This confirms receipt of Addendum #1.

THIS FORM MUST BE IN YOUR SEALED BID.

Sincerely,

Don Brockman

Don Brockman
Purchasing Agent