



City of San Leandro
Purchasing Division



Addendum No. 1 to bid specifications 08-09.020 Generator Inspections

April 16, 2009

INFORMATIONAL ITEM

Attached are pages 2 and 3 of the BAAQMD Permit to Operate for the City of San Leandro as relating to the generator(s) in bid 08-09.020 for your information.


All other remains the same

Don Brockman

Signature of Bidder

This confirms receipt of Addendum #1.

Don Brockman, Purchasing Agent, City of San Leandro


**BAY AREA AIR QUALITY
MANAGEMENT DISTRICT**

 605 ELLIS STREET
 SAN FRANCISCO, CALIFORNIA 94109
 (415) 771-8000

**PERMIT
TO OPERATE**

Plant# 15678

Page: 2

Expires: APR 1, 2011

This document does not permit the holder to violate any District regulation or other law.

 *** PERMIT CONDITIONS ***

 =====


COND# 22820 applies to S# 1

1. The owner/operator shall not exceed 20 hours per year per engine for reliability-related testing.
 [Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection (e) (2) (A) (3) or (e) (2) (B) (3)]

2. The owner/operator shall operate each emergency standby engine only for the following purposes: to mitigate emergency conditions, for emission testing to demonstrate compliance with a District, State or Federal emission limit, or for reliability-related activities (maintenance and other testing, but excluding emission testing). Operating while mitigating emergency conditions or while emission testing to show compliance with District, State or Federal emission limits is not limited.
 [Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection (e) (2) (A) (3) or (e) (2) (B) (3)]

3. The owner/operator shall operate each emergency standby engine only when a non-resettable totalizing meter (with a minimum display capability of 9,999 hours) that measures the hours of operation for the engine is installed, operated and properly maintained.
 [Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection(e) (4) (G) (1)]

4. Records: The owner/operator shall maintain the following monthly records in a District-approved log for at least 36 months from the date of entry (60 months if the facility has been issued a Title V Major Facility Review Permit or a Synthetic Minor Operating Permit). Log entries shall be retained on-site, either at a central location or at the engine's location, and made immediately available to the District staff upon request.
 - a. Hours of operation for reliability-related activities (maintenance and testing).
 - b. Hours of operation for emission testing to show compliance with emission limits.
 - c. Hours of operation (emergency).



Plant# 15678

Page 3

Expires: APR 1, 2011

This document does not permit the holder to violate any District regulation or other law

*** PERMIT CONDITIONS ***

=====

- d. For each emergency, the nature of the emergency condition.
- e. Fuel usage for each engine(s).

[Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection (e)(4)(I), (or, Regulation 2-6-501)]

5. At School and Near-School Operation:

If the emergency standby engine is located on school grounds or within 500 feet of any school grounds, the following requirements shall apply:
The owner/operator shall not operate each stationary emergency standby diesel-fueled engine for non-emergency use, including maintenance and testing, during the following periods:

- a. Whenever there is a school sponsored activity (if the engine is located on school grounds)
- b. Between 7:30 a.m. and 3:30 p.m. on days when school is in session. "School" or "School Grounds" means any public or private school used for the purposes of the education of more than 12 children in kindergarten or any of grades 1 to 12, inclusive, but does not include any private school in which education is primarily conducted in a private home(s). "School" or "School Grounds" includes any building or structure, playground, athletic field, or other areas of school property but does not include unimproved school property.

[Basis: "Stationary Diesel Engine ATCM" section 93115, title 17, CA Code of Regulations, subsection (e)(2)(A)(1) or (e)(2)(B)(2)]

~~~~~ END OF CONDITIONS ~~~~~